



SUPPLEMENTAL/BID BULLETIN

ADDENDUM NO. 01

Supply, Delivery and Commissioning of One (1) set Brand New Ultrasonic Flowmeter

This Addendum is issued to modify or amend items in the Bid Documents. This shall form an integral part of the Bidding Documents.

ISSUES	CLARIFICATION/AMENDMENT
<p>Section VII. Technical Specifications</p> <p>A. General</p> <p>Repeatability ± 0.15 % of reading Accuracy ± 0.5 % of reading</p> <p>D. Special Features</p> <p>Memory Must have built-in data logger capable of storing data. Data can be exported to a PC / laptop via RS 232 or USB cable.</p> <p>Measurement Must be able to measure pipe wall thickness.</p>	<p>Section VII. Technical Specifications</p> <p>A. General</p> <p>Repeatability ± 0.15 % of reading @ 0.005m/s or better Accuracy ± 0.5 % of reading @ 0.005m/s or better</p> <p>D. Special Features</p> <p>Memory Must have built-in data logger capable of storing data. Data can be exported to a PC / laptop via RS 232 or USB cable.</p> <p>Measurement Must be able to measure pipe wall thickness. Capable of temperature compensation</p>

For guidance and information of all concerned.

(Sgd.) GENELYN E. CABALLO
Vice Chairman – CKWD Bids and Awards Committee

Date Published: December 7, 2020