



**SUPPLEMENTAL BID BULLETIN**

**ADDENDUM NO. 01**

**SCHEDULE E – SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF ONE (1)  
UNIT 60 CUBIC METER CAPACITY FABRICATED PANEL BOLTED WATER TANK**

This Addendum No. 01 is issued to modify or amend items in the Bid Documents. This shall form an integral part of the Bidding Documents.

ISSUES	CLARIFICATION / AMENDMENT
<p><b>Section III. Bid Data Sheet</b> ITB Clause 5.3</p> <p>Completed within two (2) years prior to the deadline for the submission and receipt of bids.</p>	<p><b>Section III. Bid Data Sheet</b> ITB Clause 5.3</p> <p>Completed within <b>five (5)</b> years prior to the deadline for the submission and receipt of bids.</p>
<p><b>Section VII. Technical Specifications</b> Item No. 1 General Specifications</p> <p>Stub out: 100mm diameter on Inlet, with mating flange 150mm diameter on Outlet, with mating flange 50mm diameter on Overflow, with suitable cover and netting</p>	<p><b>Section VII. Technical Specifications</b> Item No. 1 General Specifications</p> <p>Stub out: <b>Manufacturer's Standard</b></p>
<p><b>Section VII. Technical Specifications</b> Item No. 5 Additional Requirements</p> <p>h. Notarized Certificate certifying that they have installed 1,000 cubic meters minimum of GRP Sectional water tank from authorized distributor.</p>	<p><b>Section VII. Technical Specifications</b> Item No. 5 Additional Requirements</p> <p>h. Notarized Certificate certifying that they have installed <b>100 cubic meters</b> minimum of GRP Sectional water tank from authorized distributor.</p>
<p><b>Section VII. Technical Specifications</b> Item No. 5 Additional Requirements</p> <p>Certification on similar project GRP within a year from authorized distributor.</p>	<p><b>Section VII. Technical Specifications</b> Item No. 5 Additional Requirements</p> <p>Certification on similar project GRP within <b>five (5) years</b> from authorized distributor.</p>

For guidance and information of all concerned.

(Sgd.) **ENGR. JONATHAN Q. GADAYAN**  
*Chairperson – CKWD Bids and Awards Committee*

*Date Published: December 20, 2021*