

## Republic of the Philippines CITY OF KORONADAL WATER DISTRICT

Blk. 1, Casa Subd., Brgy. Zone III, City of Koronadal Tel nos. (083)228-4049, \$20-0674, Fax no. (083)228-8141 E-mail Address: ckwd\_koronadalcity@yahoo.com Website: www.ckwd.gov.ph



## SUPPLEMENTAL BID BULLETIN

## ADDENDUM NO. 01

## SUPPLY AND DELIVERY OF VARIOUS BRASS WATER METER FOR 2024

This Addendum No. 01 is issued to modify or amend items in the Bid Documents. This shall form an integral part of the Bidding Documents.

ISSUES	CLARIFICATION / AMENDMENT
Section VII. Technical Specifications	Section VII. Technical Specifications
Item no. 2 Brass Water Meter 25mm (1")	Item no. 2 Brass Water Meter 25mm (1")
Length without tail piece: at least 266mm Weight without tail piece: at least 2.50kgs. Weight tail piece: at least 3.0kgs	Length without tail piece: at least 255 mm Weight without tail piece: at least 2.08 kgs. Weight with tail piece: at least 2.70 kgs

For guidance and information of all concerned.

(Sgd.) **ENGR. JONATHAN Q. GADAYAN**Chairperson – CKWD Bids and Awards Committee

Date Published: December 7, 2023